

One Highwood Drive, Suite 301
Tewksbury, Massachusetts 01876
Office 978.770.2031
Facsimile 978.770.2056

August 29, 2016

Mr. Gino Carlucci
Town Planner
Town of Dover
5 Springdale Avenue
Dover, MA 02030

Subject: Additional Response to Stormwater Design Review Comment
Dover Landfill Solar Project
Dover, Massachusetts

Dear Mr. Carlucci,

On behalf of BWC Buckmaster Pond, LLC, Kennedy/Jenks Consultants, Inc. (Kennedy/Jenks) has prepared this response letter to the following Dover landfill solar project stormwater design peer review comment from Tata &Howard/Civil & Environmental Consultants (CEC):

Comment: *[Kennedy/Jenks] should review their proposed time of concentration flow paths.*


Response: Kennedy/Jenks has reviewed the proposed time of concentration flow plans and have determined that they are appropriate for the stormwater model provided in the Stormwater Report, Revision 1, dated August 17, 2016 (the Stormwater Report). Specifically, the flow paths presented in Figure 1 and Figure 2 of the Stormwater Report are approximate, and represent the flow paths between the two “hydrologically most distant” points in each drainage basin, in accordance with guidance provided in Water Resources Engineering (Mays 2004)¹. Generally, the approximate point of highest elevation was identified for each drainage basin and the pre- or post-developed topography was followed, as applicable, along approximately the longest flow path until the lowest point for the flow path was reached. If the flow path that began at the highest point in the drainage basin resulted in a flow path significantly shorter than a flow path that began at a lower elevation, the longer flow path was selected to meet the “hydrologically most distant” criteria.

¹ Mays, L. W. (2004). Water Resources Engineering, 2005 Edition. John Wiley & Sons.

Stormwater Design Response to Comments
Dover Landfill Solar Project
Page 2

If you have additional questions or comments, please feel free to contact me at maxlamson@kennedyjenks.com or (978) 770-2043.

Very truly yours,
KENNEDY/JENKS CONSULTANTS, INC.



Max E. Lamson
Senior Project Manager

Cc: Mr. Jonathan Mancini, BWC Buckmaster Pond, LLC
Mr. Craig Hughes, Town of Dover
Mr. Samuel Forge, Civil & Environmental Consultants
Mr. Jonathan O'Brien, Tata&Howard