

Location for
Dumpster



Repaint "No Parking"
Markings
4/21/16



Saplings to Remove for
Dumpster 4/21/16





Views from Back
of 14 Dedham St.
Building 4/22/16



Views from Back
of 14 Dedham St.
Building 4/22/16

TOWN OF DOVER



FIRE DEPARTMENT

1 WALPOLE STREET
BOX 303
DOVER, MASSACHUSETTS 02030

TEL. 508-785-1130
FAX 508-785-8122

April 20, 2016

Mr. Gino Carlucci
Town Planner
Dover Town House
P.O. Box 250
Dover, Massachusetts 02030

Re: Proposed Dunkin Donuts Building

Dear Gino,

In response to your April 14, 2016 email regarding the proposed Dunkin Donuts at Springdale Crossing. There are no code requirements for the building to have an automatic sprinkler system installed. It is my understanding the part of the building that is to be occupied by the proposed Dunkin Donuts has an existing fire alarm system. I and the Building Official will review any plans and issue the proper permits when and if needed.

If you have any questions please feel free to contact me.

Thank You,

A handwritten signature in cursive script that reads "David Tiberi".

David W. Tiberi
Fire Inspector
Dover Fire Department
PO Box 303
1 Walpole Street
Dover, Massachusetts 02030

Office: 508-283-5225
Fax: 508-785-8122
E-mail: doverfire@doverma.org